

SAFE DRINKING AND WATER AND SANITARY CONDITION


CERTIFICATE

Ref. no.....198.....

Date.....28.01.2021.....

It is certified that an inspection team headed by **Tula Ram Mahto** S.I. (Sanitary Inspector) from Jharkhand Mineral Area Development Authority (M.A.D.A) Circle Baghmara . inspected the **Sanskar Gayanpeeth** ,(Run by Birsa Munda Educational Trust) at Peeyush Vihar Harina Nawagarh District- Dhanbad Jharkhand , on 24th January 2021 and found that **Sanskar Gayanpeeth** , has safe drinking water facilities for the students and members of staff of institution and is maintaining the hygienic sanitation condition in the school building & the campus as per as the norms prescribed by the Central / State /U.T. Gov.

The above valid for a period of Three years from the date of Issued certificate .


Signature with Seal

(Tula Ram Mahto)

Sanitary Inspector

Sanitary Inspector
JMADA
Circle-Baghmara

To
Principal /Manager
Sanskar Gayanpeeth
Peeyush Vihar Harina
Nawagarh Dist- Dhanbad
(Jharkhand)

District Level Water Testing Laboratory, Dhanbad
Drinking Water & Sanitation Department
Dhanbad, 826001 Jharkhand

Collected Sample source- *Ground Water*

Name.....

Serial No. *291/19*

Location- *Sanskar Gyanpeeth*

Date *16-9-19*

Harsana, Nalondah, Dhanbad

Water Quality Report

Parameter	Iron	Nitrate	Fluoride	Chloride	TDS	pH	Alkalinity	Hardness	Arsenic	Turbidity	Bacteri
Acceptable limit	0.3mg/l	45mg/l	1.0mg/l	250mg/l	500mg/l	6.5mg/l	200mg/l	200mg/l	0.01mg/l	INTU	Level
Permissible limit (in the absence of alternate source)	1.0mg/l	45mg/l	1.5mg/l	1000mg/l	2000mg/l	8.5mg/l	600mg/l	600mg/l	0.05mg/l	5NTU	Level
Result	<i>1.52</i>	<i>—</i>	<i>1.45</i>	<i>—</i>	<i>525</i>	<i>6.8</i>	<i>210</i>	<i>130</i>	<i>—</i>	<i>1.7</i>	<i>—</i>

(Safe.....)
(Unsafe.....)

16/09/19
Lab Analyst
D.L. W.T.L. Dhanbad

Shankar
Technical Manager
D.L. W.T.L. Dhanbad

